

**Analytical Report Nr.**

AR-21-YL-000842-01

**Sample code Nr.**

560-2021-00000765

**Date**

28/01/2021

**ANALYTICAL REPORT****Client Information**

Eurofins Polska Sp. z o.o.  
ul. Księcia Ziemowita 53 blok 3A lok. 4  
WARSZAWA POLAND

NataliaPapaja-Liczberska@eurofins.com

For the attention of Natalia Papaja-Liczberska

**Sample Information**

**Order Code:** EUAA70-00010267  
**Reception Date:** 22-Jan-2021  
**Analysis Starting Date:** 22-Jan-2021  
**Analysis Ending Date:** 28-Jan-2021  
**Sample code Nr.** 560-2021-00000765  
**Sample described as:** Masks

**Requirements and decision rule**

**Customer requirements:** EN 14683:2019+AC:2019 TYPE II  
**Decision Rule:** Shared risk - Simple acceptance.

**Information provided by the customer\***

**Client Reference:** 720-2021-00012752  
**Sample Description:** Biomask type II , Przedsiębiorstwo Produkcyjno-Handlowo-Usługowe  
"ADRIANNO-DAMIANII" Eksport-Import Leon Kajfasz  
**Purchase Order Number:**

**Batch** Not provided

**Analytical Report Nr.**

AR-21-YL-000842-01

**Sample code Nr.**

560-2021-00000765

**Date**

28/01/2021

**SAMPLE PICTURE**

**Analytical Report Nr.**

AR-21-YL-000842-01

**Sample code Nr.**

560-2021-00000765

**Date**

28/01/2021

**CONCLUSION:**

TEST PROPERTY	PASS	FAIL	REMARKS
<b>Breathability (Differential Pressure)</b> EN 14683:2019+AC:2019 Annex C			
Mask	X		

**Remark:** Test has been performed as per application request

Analytical Report Nr.

AR-21-YL-000842-01

Sample code Nr.

560-2021-00000765

Date

28/01/2021

## COMPONENT LIST:

COMPONENT ID	COMPONENT NAME	MATERIAL DESCRIPTION	COLOR	REMARKS
CUST 01	Mask	Mask	Blue	---

Analytical Report Nr.

AR-21-YL-000842-01

Sample code Nr.

560-2021-00000765

Date

28/01/2021

MASKS TESTING	CAS No.	RESULTS	UNC.	LOQ	GUIDELINES
---------------	---------	---------	------	-----	------------

**Analyses on:Mask****Breathability (Differential Pressure)**

Analysis Ending Date: 28/01/2021

**EN 14683:2019+AC:2019 Annex C**

Differential pressure

39.8 Pa/cm<sup>2</sup> (± 1.6) Pa/cm<sup>2</sup>

-

<40 Pa/cm<sup>2</sup>

✓ Pass

Complete test data reported at Annex.

**Analytical Report Nr.**

AR-21-YL-000842-01

**Sample code Nr.**

560-2021-00000765

**Date**

28/01/2021

**Signed for and on behalf of Eurofins Textile Testing Spain:**

Report electronically validated by

**Axel Ferrando**

Physical-Mechanical Lab Manager

---

**EXPLANATORY NOTE**

---

- ◆ Test not covered by ENAC accreditation scope
- Test is subcontracted within Eurofins group and is accredited
- Test is subcontracted within Eurofins group and is not accredited
- Test is subcontracted outside Eurofins group and is accredited
- Test is subcontracted outside Eurofins group and is not accredited

N/A = Not Applicable

---

\*Eurofins Textile Testing Spain S.L.U is not responsible of the information supplied by the costumer and reported as section "Information provided by the costumer\*".

Eurofins General Sales Terms and Conditions Applied.

Results obtained refer only to samples, products or material received in Laboratory, as described in section "Sample information" and tested in conditions shown in present report.

Test uncertainties not reported are at customer disposal, for those tests in which it is possible to evaluate the test uncertainty.

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor  $k = 2$ , which for a normal distribution provides a level of confidence of approximately 95%.

Reproduction of this document is only valid if it is done completely and under the written permission. Any printed version of this document will be considered as a copy.

If you happen to have any comments, please do it by sending email to [textile\\_spain@eurofins.com](mailto:textile_spain@eurofins.com) and referring to this report number.

---

**End Of Report**

---

**Eurofins Textile Testing Spain, S.L.U.**

Calle Germán Bernácer, 4

03203 Elche

SPAIN

**Phone**+34 966 299 638**www.eurofins.com/tex**

ENAC is signatory of EA and ILAC Multilateral Agreement for testing  
Activities not covered by ENAC accreditation are marked with ◆ ○ ● ■

## METHOD FOR DETERMINATION OF BREATHABILITY (DIFFERENTIAL PRESSURE)

**Test Method:** EN 14683: 2019+AC: 2019 Annex C

**Number of test specimens:** 5

**Number of test per specimen:** 5

**Sample area tested:** Circular, diameter 2,5 cm


**Tested area of the test sample:** 4,9 cm<sup>2</sup>

**Flow rate during testing:** 8±0,6 l/min

**General location of measurement areas:** Representative of the overall surface.

**Conditioning:** T<sup>a</sup> between 16,7°C and 26°C. RH between 82,8% and 88% during at least 4 h.

**Airflow direction during testing:** From the inner layer to the outer layer.



## Results

Specimen	Units (Pa)						$\Delta P$ (Pa/cm <sup>2</sup> )
	Position 1	Position 2	Position 3	Position 4	Position 5	Mean value (Pa)	
1	197	192	175	180	177	184	37,6
2	201	183	187	198	177	189	38,6
3	229	191	222	197	181	204	41,6
4	197	189	196	201	165	190	38,7
5	225	206	199	210	202	208	42,5
						<b>Mean Value</b>	<b>39,8</b>
						<b>Uncertainty</b>	<b>± 1,6</b>

## Observation:

For thick and rigid masks the test method may not be suitable as a proper seal cannot be maintained in the sample holder.

Operating requirements for surgical masks based on EN 14683: 2019+AC: 2019 standard

TEST	TYPE I	TYPE II	TYPE IIR
Bacterial filtration efficiency (BFE), (%)	≥ 95	≥ 98	≥ 98
Differential pressure (Pa/cm <sup>2</sup> )	< 40	< 40	< 60
Splash resistance pressure (kPa)	Not required	Not required	≥ 16
Microbial cleanliness (CFU/g)	≤ 30	≤ 30	≤ 30